
City of Portland, Indiana
Wet Weather Pump Station
Contract 4A

ADDENDUM 3

February 27, 2024

Planholders on the City of Portland, Indiana, Wet Weather Pump Station Contract 4A are hereby notified of the following amendments to the Contract Documents. This Addendum is hereby made a part of the Contract Documents.

GENERAL NOTES

On sheet PE-1.0, as a clarification, piping should be installed for both the primary and backup sampler, but only one sampler is required.

SPECIFICATIONS

In specification 14300 paragraph 4.01-B-3-a, the hoist's trolley should be motorized and also explosion proof.

RECEIPT OF THIS ADDENDUM MUST BE ACKNOWLEDGED ON THE BID.