



Village of Oak Harbor, Ohio
Salem Township Pump Stations Rehabilitation

ADDENDUM 2

March 27, 2024

Planholders on the Village of Oak Harbor, Ohio; Salem Township Pump Stations Rehabilitation are hereby notified of the following amendments to the Contract Documents. This Addendum is hereby made a part of the Contract Documents.

CLARIFICATIONS

The 8-inch sanitary sewer east from Pump Station 1 is a future stub, capped approximately 10 feet east of the pump station.

SPECIFICATIONS

Page 11731-9, Paragraph 2.04 G. 1. k.

At the end of the sentence, delete "SCADA" and replace with "RTU".

Page 11731-9, Paragraph 2.04 G. 1. l. 1)

Delete Paragraph 1) in its entirety, and replace with "1) Wet Well Level (ft).".

Page 11731-9, Paragraph 2.04 G. 1. m.

In the first line, delete the words "via modbus".

Planholders should update the Table of Contents to reflect the above sections.

An updated Table of Contents will be included in the Issued for Construction Project Manual.

RECEIPT OF THIS ADDENDUM MUST BE ACKNOWLEDGED ON PAGE C-410-1 OF THE BID.