

---

City Of Carmel  
Well 29

---

---

**ADDENDUM 2**

---

November 26, 2024

Planholders on the City of Carmel Well 29 project are hereby notified of the following amendments to the Contract Documents. This Addendum is hereby made a part of the Contract Documents.

**GENERAL COMMENTS**

Developing the well using the twin disc surge method is acceptable.

The Contractor will not be required to provide warranties on items purchased by the Utility.

There are no prevailing wage requirements for this project.

There is no AIS requirement for this project; however, Carmel Utilities requires that all fittings and valves be manufactured in the United States.