



City Of Carmel
West Ground Storage Tank

ADDENDUM 5

November 27, 2024

Planholders on the City of Carmel Ground Storage Tank project are hereby notified of the following amendments to the Contract Documents. This Addendum is hereby made a part of the Contract Documents.

GENERAL NOTES

Bidders may assume the following of site conditions exist without the need for additional ground improvement or a deep foundation system:

1. Design groundwater elevation will be elevation 918.5'.
2. The minimum gross allowable bearing capacity of the soil is 3,000 psf.
3. Total settlement will be less than 2".
4. Differential settlement will be less than 0.5".